



Water Service Pipe Material Identification

| | Lead | Galvanized Iron | Copper | Brass |
|-----------------------------------|--|---|---------------------------------------|---------------------------------------|
| Outer Appearance | Dull gray, bendable; Often curves between wall/floor and valve | Dark gray or black; Straight rigid pipe | Brown; Can have green corrosion spots | Brown; Can have green corrosion spots |
| Threads at connections | None | Yes | None | Yes |
| Scratch Test (coin or key) | Shiny silver | Hard to scratch, remains gray | Copper, like a penny | Gold color |
| Magnet Test | Does not stick | Magnet WILL stick | Does not stick | Does not stick |


Lead



Galvanized Iron



Copper



Brass

